



CHM @ LOGAN ES LEAD WATER TEST RESULTS



Initial Filter Test After Installation

	Building Location: Building Name	RECORD ID	Date Analyzed	Floor	Device Type	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	Final Result - 2nd Draw (ppb)
1	CAPITOL HILL MONTESSORI ELEMENTARY SCHOOL @ LOGAN	WS- 000004	12/23/2016	1	Break Room	Annex building in staff lounge area	FT-102016-000004-A	< 1	FT-102016-000004-B	< 1
2	CAPITOL HILL MONTESSORI ELEMENTARY SCHOOL @ LOGAN	WS- 000034	12/23/2016	1	Classroom Faucet	In classroom 108 (nap room)	FT-122016-000034-A	< 1	FT-122016-000034-B	< 1
3	CAPITOL HILL MONTESSORI ELEMENTARY SCHOOL @ LOGAN	WS- 000037	12/23/2016	1	Classroom Faucet	In classroom 109	FT-122016-000037-A	< 1	FT-122016-000037-B	< 1
4	CAPITOL HILL MONTESSORI ELEMENTARY SCHOOL @ LOGAN	WS- 000046	12/23/2016	1	Classroom Faucet	In classroom 107	FT-122016-000046-A	< 1	FT-122016-000046-B	< 1
5	CAPITOL HILL MONTESSORI ELEMENTARY SCHOOL @ LOGAN	WS- 000047	12/23/2016	1	Classroom Faucet	In classroom 110	FT-122016-000047-A	< 1	FT-122016-000047-B	< 1
6	CAPITOL HILL MONTESSORI ELEMENTARY SCHOOL @ LOGAN	WS- 000050	12/23/2016	1	Classroom Faucet	In classroom 111	FT-122016-000050-A	1	FT-122016-000050-B	< 1
7	CAPITOL HILL MONTESSORI ELEMENTARY SCHOOL @ LOGAN	WS- 000051	12/23/2016	1	Break Room	In admin 106 personnel kitchen	FT-102016-000051-A	< 1	FT-102016-000051-B	< 1
8	CAPITOL HILL MONTESSORI ELEMENTARY SCHOOL @ LOGAN	WS- 000054	12/23/2016	1	Classroom Faucet	In classroom 105 - Library High Left	FT-122016-000054-A	< 1	FT-122016-000054-B	< 1
9	CAPITOL HILL MONTESSORI ELEMENTARY SCHOOL @ LOGAN	WS- 000055	12/23/2016	1	Classroom Faucet	In classroom 105 - Library Low Right	FT-122016-000055-A	< 1	FT-122016-000055-B	< 1
10	CAPITOL HILL MONTESSORI ELEMENTARY SCHOOL @ LOGAN	WS- 000058	12/23/2016	1	Classroom Faucet	In classroom 101	FT-122016-000058-A	< 1	FT-122016-000058-B	< 1
11	CAPITOL HILL MONTESSORI ELEMENTARY SCHOOL @ LOGAN	WS- 000061	12/23/2016	1	Classroom Faucet	In classroom 104	FT-122016-000061-A	< 1	FT-122016-000061-B	< 1
12	CAPITOL HILL MONTESSORI ELEMENTARY SCHOOL @ LOGAN	WS- 000064	12/23/2016	1	Classroom Faucet	In classroom 102	FT-122016-000064-A	< 1	FT-122016-000064-B	< 1
13	CAPITOL HILL MONTESSORI ELEMENTARY SCHOOL @ LOGAN	WS- 000067	12/23/2016	2	Break Room	In teachers lounge 214	FT-102016-000067-A	< 1	FT-102016-000067-B	< 1
14	CAPITOL HILL MONTESSORI ELEMENTARY SCHOOL @ LOGAN	WS- 000070	12/23/2016	2	Classroom Faucet	In art room 213 sink Left	FT-122016-000070-A	< 1	FT-122016-000070-B	< 1
15	CAPITOL HILL MONTESSORI ELEMENTARY SCHOOL @ LOGAN	WS- 000071	12/23/2016	2	Classroom Faucet	In art room 213 Right	FT-122016-000071-A	< 1	FT-122016-000071-B	< 1
16	CAPITOL HILL MONTESSORI ELEMENTARY SCHOOL @ LOGAN	WS- 000076	12/23/2016	2	Classroom Faucet	In classroom 203	FT-122016-000076-A	< 1	FT-122016-000076-B	< 1
17	CAPITOL HILL MONTESSORI ELEMENTARY SCHOOL @ LOGAN	WS- 000078	12/23/2016	2	Classroom Faucet	In classroom 202	FT-122016-000078-A	< 1	FT-122016-000078-B	< 1
18	CAPITOL HILL MONTESSORI ELEMENTARY SCHOOL @ LOGAN	WS- 000084	12/23/2016	2	Classroom Faucet	In classroom 201	FT-122016-000084-A	< 1	FT-122016-000084-B	< 1

First Filter Re-Test (After Filter and Plumbing Check with Aerator Replacement)

6	CAPITOL HILL MONTESSORI ELEMENTARY SCHOOL @ LOGAN	WS- 000050	1/25/2017	1	Classroom Faucet	In classroom 111	FT-122016-000050-A	1.5	FT-122016-000050-B	< 1
---	--	------------	-----------	---	------------------	------------------	--------------------	-----	--------------------	-----

Note :

Filter re-tests are only performed to devices that have sampling results greater than 1 ppb

Second Filter Re-Test (After Device Replacement)

6	CAPITOL HILL MONTESSORI ELEMENTARY SCHOOL @ LOGAN	WS- 000050	2/20/2017	1	Classroom Faucet	In classroom 111	FT-122016-000050-A	3.6	FT-122016-000050-B	< 1
---	--	------------	-----------	---	------------------	------------------	--------------------	-----	--------------------	-----

Third Filter Re-Test (Post Consultation)

6	CAPITOL HILL MONTESSORI ELEMENTARY SCHOOL @ LOGAN	WS- 000050	3/1/2017	1	Classroom Faucet	In classroom 111	FT-122016-000050-A	< 1	FT-122016-000050-B	< 1
---	--	------------	----------	---	------------------	------------------	--------------------	-----	--------------------	-----